

DESIGN ENVELOPE 4200H | END SUCTION BASE MOUNTED | SINGLE PHASE | 0408-005.0 | **SUBMITTAL**

File No: 100.3448 Date: APRIL 18, 2016 Supersedes: NEW Date: NEW

| Jop: | Representative: | | |
|--------------------|-----------------|-------------------------|--|
| | Order No: | Date: | |
| Engineer: | Submitted by: | Date: | |
| Contractor: | Approved by: | Date: | |
| PUMP DESIGN DATA | CONTROLS DATA | | |
| No. of pumps: Tag: | Power su | pply: Volts: 200-240VAC | |

| · · _ | | | | Freq: 50/60Hz Phase: 1 |
|---|--|----------------------|---|---|
| | | Head:ft (m) | Sensorless control: | Standard |
| | | Viscosity: | Minimum system pressure | |
| Temperature: | °F (°C) | Specific gravity: | • | ft (m)* |
| Suction: 6"(150mm) Tapped holes | | | Protocol (standard): | □ Modbus rtu □ bacnet™ ms/tp □ Johnson® n2 □ Siemens® fln |
| Discharge: 4"(100mm) Flanged | | | Protocol (optional): | □ LonWorks [®] |
| ul std 778 & csa std c22.2 no.108 certified | | Enclosure: | □ Indoor – UL TYPE 12 | |
| | | Disconnect switch: | \Box Non-fused | |
| MOTOR DES | IGN DATA | | ЕМІ/RFI control: | 1-phase IVS102 units do not meet the EN61800-3 directive |
| HP: 5 | rpm: 1800 | Frame size: 184TC_ | Harmonic suppression: | Dual DC-link reactors (Equivalent: 5% Ac line reactor) Supporting IEEE 519-1992 requirements** |
| Enclosure: TEFC | Volts: 208 | Freq: 60 Hz | Cooling: | Fan-cooled through back channel |
| Phase: 3 Efficiency: NEMA premium 12.12 | | Ambient temperature: | -10°C to +45°C up to 1000 meters above sea level (-14°F to +113°F, 3300 ft) | |
| MAXIMUM PU | UMP OPERAT | ING CONDITIONS | Analog ı/o: | Two current or voltage inputs, one current output |
| ANSI 125 | | | Digital ı/o: | Six programmable inputs (two can be configured as outputs) |
| 175 psig at 140°F (12 bars at 60°C) | | Pulse inputs: | Two programmable | |
| 100 psig at 300°F (7 bars at 149°C) | | Relay outputs: | Two programmable | |
| ANSI 250 | | | Communication port: | 1-rs485, 1-usb |
| | : (26 bars at 38°C) F (19 bars at 149°(| | **The IVS 102 drive is a low harmonic d | ure is not known: Default to 40% of design head Irive via built-in ɒc line reactors. This does not |
| Tolerance of ±0.125" (±3 mm) should be used | | • | n wide harmonic specification or the costs to meet ied with the system electrical details. Armstrong | |

.....

••••••

- For exact installation, data please write factory for certified dimensions
- Pump equipped with casing drain plug and 1/4" NPT suction and discharge gauge ports

OPTIONAL EQUIPMENT

MECHANICAL SEAL DATA

| Seal type: AB2 | | |
|-------------------------|--|--|
| Secondary seal: Viton | | |
| Spring: Stainless steel | | |


and the costs for such mitigation.

Stationary seat: Sintered silicon carbide Rotating hardware: Stainless steel

will run a computer simulation of the system wide harmonics. If system harmonic levels are exceeded Armstrong can also recommend additional harmonic mitigation

2

EXTENDED SPEED



нс

HI

2HF

нв

0 0 0

Performance curves are for reference only. Confirm current performance data with Armstrong ACE Online selection software.

DIMENSION DATA

| | INDOOR |
|-----------------|------------------|
| | (UL TYPE 12/ODP) |
| Frame size: | 184TC |
| Size: | 6×4×8 |
| HP: | 5 |
| RPM: | 1800 |
| HA: | 14.00 (355) |
| HB: | 30.00 (762) |
| HC: | 30.63 (778) |
| HD: | 11.25 (286) |
| HE: | 6.37 (162) |
| HF: | 13.00 (330) |
| 2HF: | 26.00 (660) |
| HG: | 3.00 (76) |
| HI: | 28.96 (736) |
| HL: | 4.50 (114) |
| HV: | 17.05 (433) |
| NaN1: | 2.00 (51) |
| NaN2: | 7.17 (182) |
| х: | 11.00 (279) |
| Y: | 4.00 (102) |
| Weight: | 441 (200.2) |
| Dimensions – in | |

нν

HD

HE

HA

Weight – Ibs (kg)

NAN2

INDOOR

TORONTO +1 416 755 2291

BUFFALO +1 716 693 8813

BIRMINGHAM +44 (0) 8444 145 145

MANCHESTER

+44 (0) 8444 145 145

BANGALORE +91 (0) 80 4906 3555

SHANGHAI +86 21 3756 6696

> ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934

HF

NAN1-

ARMSTRONGFLUIDTECHNOLOGY.COM

HĿ

∎нс

+55 11 4781 5500

SÃO PAULO