

DESIGN ENVELOPE 4300 VIL

SINGLE PHASE | 0306-005.0 | SUBMITTAL

File No: 100.4284

Date: OCTOBER 27, 2014

Supersedes: NEW


Date: NEW

Job:	Represe	entative:		
	Order N	No:	Date	:
Engineer: Sub Contractor: App		ted by:		
		red by:		
PUMP DESIGN DATA	;	CONTROLS DATA		
No. of pumps: Tag: Capacity: USgpm (L/s) Hea	:	Power supply:	Volts: 200-240V/ Freq: 50/60Hz	AC Phase: 1
Liquid: Visc	:	Sensorless Control:	Standard	
Temperature: °F (°C) Spec Suction: 3" (75mm) Disc	ecific gravity: charge: 3" (75mm)	Minimum system pressure to be maintained:		ft (m)*
Suction: 3 (/5mm) Disc	charge. 3 (/5mm)	Orientation: Protocol (standard):	☐ L1 (default) ☐	
MOTOR DESIGN DATA		Protocoi (Standard):	☐ Johnson® N2	
	_ :	Protocol (optional):	Protocol (optional): □ LonWorks®	
нр: 5		Enclosure: ☐ Indoor – UL TYPE 12 ☐ Outdoor – UL TYPE 4X with Weather Shield		
Phase: 3 Efficiency: NEMA p	premium		☐ Outdoor - UL T	
		Disconnect switch:	\square Non-fused	
MAXIMUM PUMP OPERATING CONDITIONS		емі/RFI control:	1-phase IVS102 units do not meet the EN61800-3 directive	
ANSI 125 175 psig at 150°F (12 bars at 65°C) 100 psig at 300°F (7 bars at 150°C)		Harmonic suppression:	Dual DC-link reactors (Equivalent: 5% AC line reactor) Supporting IEEE 519-1992 requirements**	
ANSI 250		Cooling:	Fan-cooled throu	gh back channel
375 psig at 150°F (26 bars at 65°C) 260 psig at 300°F (21 bars at 150°C)		Ambient temperature:	-10°C to +45°C up above sea level (- 3300 ft)	to 1000 meters 14°F to +113°F,
 Tolerance of ±0.125" (±3 mm) should be used For exact installation, data please write factory for certified dimensions 		Analog ı/o:	Two current or vo	
		Digital ı/o:	Six programmabl be configured as	
		Pulse inputs:	Two programmal	ble
MECHANICAL SEAL DESIGN DAT	TA :	Relay outputs:	Two programmal	ble
See file no. 43.50 for standard mechanical seal details as		Communication port:	1-RS485, 1-USB	
indicated below	:	*If minimum maintained system pressu		
Armstrong seal reference number		**The IVS 102 drive is a low harmonic drive via built-in DC line reactors. This does not guaranty performance to any system wide harmonic specification or the costs to		
☐ A1 (c) ☐ Others:		meet a system wide specification. If supplied with the system electrical details, Armstrong will run a computer simulation of the system wide harmonics. If system		

harmonic levels are exceeded Armstrong can also recommend additional harmonic

 $\label{eq:mitigation} \mbox{mitigation and the costs for such mitigation}.$

2




Performance curves are for reference only.


 $Confirm\ current\ performance\ data\ with\ Armstrong\ ACE\ Online\ selection\ software.$


DIMENSION DATA


	INDOOR (UL TYPE 12/ODP)	OUTDOOR (UL TYPE 4X/TEFC)	
Frame size:	182	182	
Size:	3×3×6	3×3×6	
HP:	5	5	
RPM:	2900	2900	
AB:	26.46(672)	32.59(828)	
в:	5.80(147)	5.80(147)	
c:	4.65(118)	4.65(118)	
D:	8.25(210)	8.25(210)	
E:	12.74(324)	17.90(455)	
F:	12.74(324)	17.90(455)	
P:	10.38(264)	9.56(243)	
s:	9.75(248)	9.75(248)	
SD:	18.00(457)	18.00(457)	
T:	6.06(154)	6.06(154)	
XY:	26.54(674)	26.42(671)	
Weight:	228(103.4)	285(129.3)	


Dimensions - inch (mm) Weight - lbs (kg)











TORONTO

+1 416 755 2291

BUFFALO

+1 716 693 8813

BIRMINGHAM

+44 (0) 8444 145 145

MANCHESTER

+44 (0) 8444 145 145

BANGALORE

+91 (0) 80 4906 3555

SHANGHAI

+86 21 3756 6696

ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934

ARMSTRONGFLUIDTECHNOLOGY.COM