IF IN DOUBT A	Sk
---------------	----

ITEM NO

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

DRAWING RELEASE LEVEL:

DESCRIPTION

BASE PLATE

BOLT - M12

WASHER - M12

CAGE NUT - M12

VMS PUMP

SUCTION/DISCHARGE MANIFOLD

ASSY

ISOLATING VALVE 1 1/2"

NRV 1 1/2"

SUPPORT RIB

STANCHION

PRESSURE TRANSDUCER

PRESSURE GAUGE

FEMALE CROSS 1/2"

ISOLATING VALVE 1/2"

AIR VENT 1/4"

CONTROL PANEL

1/2" NIPPLE

1/2" x 1/4" REDUCING BUSH

BOLT - M10

WASHER - M10

NUT - M10

CAGE NUT - M10

1/2" T

END CAP

11

NO. OFF

2

9

9

3


2


SHEET 1 OF 1

SCALE: 1:7 WEIGHT: KG

		FLC	PUMP	SET	VESSEL	WORKING	TEST				
PUMP	MOTOR	AMPS		WEIGHT			PRESSURE	STARTING	L	D	Е
SIZE	KW	3x415W	KGS	KGS	LTRS	MAX BAR	MAX. BAR	CURRENT	MM	MM	MM
SV0802	1.1	2.6	25.5	104	60	2.7	24	6	691	258	300
SV0803	1.5	3.6	32	117	60	4	24	6	739	258	300
SV0804	2.2	5	34	121	60	5.4	24	10	777	258	300
SV0805	2.2	5	35	123	60	6.8	24	10	815	258	300
SV0806	3	6.6	42	137	60	8	24	16	903	258	300
SV0808	4	8.5	58.5	170	60	10.8	24	20	983	258	300
SV0809	4	8.5	59.5	172	60	12.1	24	20	1021	258	300









CHECKED BY: -

- 1) MAIN POWER SUPPLY TO PANEL MUST BE SIZED TO COVER ALL PUMPS RUNNING AT THE SAME TIME
- 2) LARGE STORAGE VESSELS, IF ORDERED, WILL
 BE SUPPLIED LOOSE FOR POSITIONING FOR CLIENT
 TO SUIT THE AVAILABLE FLOOR SPACE.
 CLIENT IS TO PROVIDE A CONNECTION FROM THE VESSEL TO THE DELIVERY PIPEWORK ADJACENT TO THE SET ISOLATING AND DRAIN VALVES SHOULD BE FITTED IN THIS CONNECTION
- 3) 60 Lt TANK WILL BE SUPPLIED LOOSE AND SHOULD BE ASSEMBLED ON SITE
- 4) FLANGES ARE AVAILABLE BOTH IN 16 & 25 BAR VERSION

5) FOR STANCHTION SELECTION	I USE DRAWING NO. <u>PK</u>	14967							
		PART No.	UNLESS OTHERWISE SPECIFIED	NAME	DATE	ADMICTRONIC			
		JOB No.	DIMENSIONS ARE IN mm WELD SYMBOLS TO BS 499 SURFACE FINISH SHOWN IN um.	DRAWN PRAKASH 0 CHECKED	11/03/08	AKMSIKUNG			
		DESIGN No.	MACHINE WHERE SHOWN	Q.A.	TI	TLE: COOLUMD SERVE			
LAST MODIFICATION DETAILS	PROPRIETARY AND CONFIDENTIAL	PATTERN No.	TO TOLERANCE ± 0.3	MFG APPR.		6800 HMP SERIES 2PUMP SV08	, o		
-	THIS DRAWING IS THE PRIVATE AND CONFIDENTIAL PROPERTY OF ARMSTRONG. ALL COPYRIGHT, MANUFACTURING AND SALES RIGHTS RESERVED.	FILE NAME	DIMENSIONING AND TOLERANCING PER: BS 308	ENG APPR. COMMENTS:		ZPUMP 3V00			
		FINISH	MATERIAL		SIZ	ZE DRG. NO.	REV		
-			MATERIAL SPEC.	DO NOT SCAI	LE A	1 PX10740	В		




D



700

812 OVER ALL



NOTE:-(18)

DETAIL A SCALE 2:7

(17)