



| | | FLC | PUMP | SET | VESSEL | WORKING | TEST | | | | |
|--------|-------|--------|--------|--------|--------|----------|----------|----------|-----|-----|-----|
| PUMP | MOTOR | AMPS | WEIGHT | WEIGHT | SIZE | PRESSURE | PRESSURE | STARTING | L | Α | В |
| SIZE | KW | 3x415W | KGS | KGS | LTRS | MAX BAR | MAX BAR | CURRENT | MM | MM | MM |
| SV0202 | 0.55 | 1.5 | 17.5 | 105 | 60 | 2.2 | 24 | 4 | 559 | 185 | 215 |
| SV0203 | 0.55 | 1.5 | 18 | 106 | 60 | 3.1 | 24 | 4 | 584 | 185 | 215 |
| SV0204 | 0.55 | 1.5 | 19 | 108 | 60 | 4.2 | 24 | 4 | 621 | 185 | 215 |
| SV0205 | 0.55 | 1.5 | 21.5 | 113 | 60 | 5.3 | 24 | 4 | 661 | 185 | 215 |
| SV0206 | 0.75 | 1.9 | 22 | 114 | 60 | 6.3 | 24 | 6 | 686 | 185 | 215 |
| SV0207 | 0.75 | 1.9 | 23 | 116 | 60 | 7.4 | 24 | 6 | 748 | 185 | 215 |
| SV0208 | 1.1 | 2.6 | 23.5 | 117 | 60 | 8.4 | 24 | 6 | 773 | 185 | 215 |
| SV0209 | 1.1 | 2.6 | 24 | 118 | 60 | 9.4 | 24 | 6 | 798 | 185 | 215 |
| SV0211 | 1.1 | 2.6 | 31 | 132 | 60 | 11.5 | 24 | 6 | 858 | 185 | 215 |
| SV0212 | 1.5 | 3.6 | 31.5 | 133 | 60 | 12.6 | 24 | 6 | 883 | 185 | 215 |


IF IN DOUBT ASK



ANTI-VIBRATION MOUNTINGS OPTIONAL ONLY SUPPLIED WHEN ORDERED (4-PER SET K2092/10)



FLEXIBLE CONNECTORS OPTIONAL ONLY SUPPLIED WHEN ORDERED (2-PER SHEET)



NOTE:-

LAST MODIFICATION DETAILS

CHECKED BY:

1) MAIN POWER SUPPLY TO PANEL MUST BE SIZED TO COVER ALL PUMPS RUNNING AT THE SAME TIME

2) LARGE STORAGE VESSELS, IF ORDERED, WILL
BE SUPPLIED LOOSE FOR POSITIONING FOR CLIENT
TO SUIT THE AVAILABLE FLOOR SPACE.
CLIENT IS TO PROVIDE A CONNECTION FROM THE VESSEL
TO THE DELIVERY PIPEWORK ADJACENT TO THE SET
ISOLATING AND DRAIN VALVES SHOULD BE FITTED
IN THIS CONNECTION

3) 60 Lt TANK WILL BE SUPPLIED LOOSE AND SHOULD BE ASSEMBLED ON SITE

4) FLANGES ARE AVAILABLE BOTH IN 16 & 25 BAR VERSION

5) FOR STANCHION SELECTION USE DRAWING NO. PK14967

APP. BY:

| ITEM NO | DESCRIPTION | NO. OFF |
|---------|-----------------------------------|---------|
| 1 | BASE PLATE | 1 |
| 2 | BOLT - M12 | 12 |
| 3 | WASHER - M12 | 12 |
| 4 | CAGE NUT - M12 | 12 |
| 5 | VMS PUMP | 3 |
| 6 | 6 SUCTION/DISCHARGE MANIFOLD ASSY | |
| 7 | ISOLATING VALVE 1" | 6 |
| 8 | NRV 1" | 3 |
| 9 | SUPPORT RIB | 1 |
| 10 | STANCHION | 1 |
| 11 | PRESSURE TRANSDUCER | 1 |
| 12 | PRESSURE GAUGE | 1 |
| 13 | FEMALE CROSS 1/2" | 1 |
| 14 | ISOLATING VALVE 1/2" | 1 |
| 15 | AIR VENT 1/4" | 1 |
| 16 | CONTROL PANEL | 1 |
| 17 | 1/2" NIPPLE | 3 |
| 18 | 1/2" x 1/4" REDUCING BUSH | 3 |
| 19 | BOLT - M10 | 9 |
| 20 | WASHER - M10 | 9 |
| 21 | NUT - M10 | 3 |
| 22 | CAGE NUT - M10 | 6 |
| 23 | 1/2" T | 1 |
| 24 | END CAP | 2 |

SCALE: 1:8 WEIGHT: KG

11

SHEET 1 OF 1

| | | PART No. | UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN mm | DRAWN | NAME PRAKASH | DATE 03/03/08 | | ARMSTRONG | | | |
|--|--|-------------|---|----------------------|-----------------|------------------|------------|---------------------------|-----|--|--|
| | | JOB No. | WELD SYMBOLS TO BS 499 SURFACE FINISH SHOWN IN um. | CHECKED | | | | AKMSIKONO | | | |
| | | DESIGN No. | MACHINE WHERE SHOWN TO TOLERANCE ± 0.3 | Q.A. | | | TITLE | COOLUMD CEDIE | | | |
| | PROPRIETARY AND CONFIDENTIAL | PATTERN No. | DIMENSIONING AND TOLERANCING PER: | MFG APPR. | | | | 6800 HMP SERIE 3PUMP SV02 | 3 | | |
| | THIS DRAWING IS THE PRIVATE AND CONFIDENTIAL PROPERTY OF | FILE NAME | | ENG APPR. COMMENTS: | | | | SPUNF SVUZ | | | |
| | ARMSTRONG. ALL COPYRIGHT, MANUFACTURING AND | FINISH | | | | | SIZE | DRG. NO. | REV | | |
| | SALES RIGHTS RESERVED. | | MATERIAL SPEC. | DO NO | O NOT SCALE | | A 1 | PX10733 | В | | |

DRAWING RELEASE LEVEL: