

# DESIGN ENVELOPE 4200H END SUCTION 2×1.5×5 (40-125) | 1505-002.0 | SUBMITTAL

File No: 103.5442
Date: NOVEMBER 08, 202
Supersedes: NEW
Date: NEW

Job:	Representative:	
	Order No:	_ Date:
Engineer:	Submitted by:	_ Date:
Contractor:	Approved by:	_ Date:

# PUMP DESIGN DATA

No. of pumps:		Tag:
Capacity:	_USgpm (L/s)	Head:ft (m)
Liquid:		Viscosity:
Temperature:	°F (°C)	Specific gravity:
Suction: 2" (50 mm)	)	Discharge: 1.5" (40 mm)

# UL STD 778 & CSA STD C22.2 NO.108 certified

Test report is supplied with each pump

#### MATERIALS OF CONSTRUCTION

# □ ANSI 125 CONSTRUCTION: LPDESF E-coated ductile iron A536 Gr 65-45-12, stainless fitted

#### 🗆 ANSI 250

CONSTRUCTION: HPDESF E-coated ductile iron A536 Gr 120-90-2, stainless fitted

#### MAXIMUM PUMP OPERATING CONDITIONS

#### □ ANSI 125

175 psig at 150°F (12 bar at 65°C) 100 psig at 300°F (7 bar at 150°C)

# □ ANSI 250

375 psig at 150°F (26 bar at 65°C) 260 psig at 300°F (21 bar at 150°C)

# MECHANICAL SEAL DESIGN DATA

See file no. 43.50 for standard mechanical seal details as indicated below

#### Armstrong seal reference number

🗆 c1 (a) Others:

# DEPM MOTOR AND CONTROL DATA

HP:	2	
RPM:	3000	
Motor enclosure:	TEFC	
Volts / Phase	: □ 200-240V/1ph □ 380-480V/3ph	
	For 200-240V/3ph or 575V/3ph, see File #: 103.5405	
Efficiency:	IE5	
Protocol (standard):	□ BACNEt <sup>™</sup> MS/TP □ BACNEt <sup>™</sup> TCP/IP	
	□ Modbus rtu	
Control enclosure:	□ Indoor – UL TYPE 12	
Fused disconnect switch:	See File 100.8131	
ЕМІ/RFI control:	Integrated filter designed to meet EN61800-3	
Harmonic suppression:	Equivalent: 5% Ac line reactor - Supporting IEEE 519-1992 requirements**	
Cooling:	Fan-cooled, surface cooling	
Ambient temperature:	-10°C to +40°C up to 1000 meters above sea level (+14°F to +104°F, 3300 ft)	
Analog ı/o:	Two inputs, one output. Output can be configured for voltage or current	
Digital ı/o:	Two inputs, two outputs. Outputs can be configured as inputs	
Relay outputs:	Two programmable	
Communication port:	1-RS485	

\*\* If supplied with the system electrical details, Armstrong will run a computer simulation of the system wide harmonics. If system harmonic levels are exceeded Armstrong can also recommend additional harmonic mitigation and the costs for such mitigation.

#### FLOW READOUT ACCURACY

The Design Envelope model selected will provide flow reading on the controls local keypad & digitally for the BMS. The model readout will be factory tested to ensure ±5% accuracy.

#### 2

# OPTIONS

#### SENSORLESS BUNDLE (STANDARD)



Operation of pump without a remote sensor. Includes:

- Sensorless control
- Flow readout
- Constant flow
- Constant pressure

Minimum system pressure to be maintained

ft (m)

\* If minimum maintained system pressure is not known: Default to 40% of design head

# PARALLEL SENSORLESS

Operation of multiple pumps without a remote sensor

Minimum system pressure to be maintained ft (m)

\* If minimum maintained system pressure is not known: Default to 40% of design head

# ENERGY PERFORMANCE BUNDLE



Provides energy savings on oversized systems by adjusting pump parameters to on-site conditions. Includes:

- Auto-flow balancing Automatically determines control curve between design flow at on-site system head, and minimum (zerohead) flow for energy savings
- Maximum flow control Limits flow rate to pre-set maximum for potential energy savings

Maximum flow rate

ow rate gpm (L/s)

\*Only available if sensorless bundle is enabled \*Available in single pump operation only

# PROTECTION BUNDLE



Protects other flow sensitive equipment by setting limits of pump operation. Includes:

- Minimum flow control Attempts to maintain flow rate to pre-set minimum to protect equipment in system
- Bypass valve control Actuates a bypass valve to protect flow sensitive equipment if pre-set minimum flow rate is reached

Minimum flow rate gpm (L/s)

\*Only available if sensorless bundle is enabled

# DUAL SEASON SETUP



Pre-sets heating and cooling parameters for pumps in 2-pipe systems



Duty point \_\_\_\_\_ gpm (L/s) at \_\_\_\_\_ ft (m) Minimum system pressure to be maintained ft (m)

# Heating

Duty point \_\_\_\_\_ gpm (L/s) at \_\_\_\_\_ ft (m) Minimum system pressure to be maintained ft (m)

\*Available in single pump operation only

# **OPTIONAL SERVICES**

# **ON-SITE PUMP COMMISSIONING**




#### PUMP MANAGER



Online service for sustained pump performance and enhanced reliability.

Available in 3 or 5 year terms

- \* Requires an internet connection to be provided by building
- \* Includes an extended warranty for parts and labour (wearable parts excluded)



USGPM

15

L/S

220

200

Size:	2×1.5×5
HP:	2
RPM:	3000
Frame:	71
HA:	10.32 (262)
HD:	8.75 (222)
HI:	16.78 (426)
HV:	5.97 (152)
x:	7.00 (178)
Y:	4.00 (102)
Free & operating height:	3.75 (95)
Weight:	71 (32.0)

DIMENSION DATA

STANDARD

# SPRING DATA

Rated Capacity per spring lbs (kgs):	54 (25.0)
Rated Deflection inch (mm):	1.20 (30)
<b>Mount Constant</b> lbs/in (kg/mm):	45 (0.8)

# SEISMIC MOUNT OPTION

2E:	5.75 (146)
F:	4.00 (102)
G:	6.00 (152)
н:	0.50 (12)
HA:	10.32 (262)
HD:	10.00 (254)
N:	7.19 (183)
Free & operating height:	5.00 (127)
Max. horizontal static G rating:	6.7

Dimensions - inch (mm) Weight - Ibs (kg)

÷

- Tolerance of  $\pm 0.125$ " ( $\pm 3$  mm) should be used

• For exact installation, data please write factory for certified dimensions

Performance curves are for reference only.

80

5

90

100

6

Confirm current performance data with Armstrong ADEPT Quote or ADEPT Select selection software.

120

8

FLOW

7

140


9


160

10

180

#### STANDARD






All springs have additional travel to solid equal to 50% of the rated deflection.


NOTE:

**SUBMITTAL** 1505-002.0

#### 4

#### STANDARD





#### SEISMIC MOUNT OPTION

**TORONTO** +1 416 755 2291

**BUFFALO** +1 716 693 8813

**DROITWICH SPA** +44 8444 145 145

**MANCHESTER** +44 8444 145 145

**BANGALORE** +91 80 4906 3555

**SHANGHAI** +86 21 5237 0909

**são paulo** +55 11 4785 1330

LYON +33 4 26 83 78 74

**dubai** +971 4 887 6775

# MANNHEIM

+49 621 3999 9858

**JIMBOLIA** +40 256 360 030 ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934

ARMSTRONGFLUIDTECHNOLOGY.COM

