

# DESIGN ENVELOPE 4200H END SUCTION

2506-007.5 | SUBMITTAL

File No: 103.5021

Date: AUGUST 1, 2018

Supersedes: 103.5021

Date: MARCH 30, 2018

Job:	Repre	Representative:		
	Orde	r No:	Date:	
Engineer: Su		nitted by:	Date:	
Contractor:	Appro	oved by:	Date:	
PUMP DESIGN DATA		CONTROLS DATA		
No. of pumps: Tag:		Protocol (standard):	☐ BACnet™ MS/TP	
Capacity:USgpm (L/s) Head:	ft (m)		☐ BACnet™ TCP/IP	
Liquid: Viscosity	:		☐ Modbus RTU	
Temperature:°F (°C) Specific g	gravity:	Enclosure:	☐ Indoor - UL TYPE 12	
Suction: 3"(75mm) Flanged		Fused disconnect switch:		
Discharge: 2.5"(60mm) Flanged		EMI/RFI control:	Integrated filter designed to meet EN61800-3	
UL STD 778 & CSA STD C22.2 NO.108 certified  Test report is supplied with each pump		Harmonic suppression:	Dual Dc-link reactors (Equivalent: 5% Ac line reactor) Supporting IEEE 519-1992 requirements**	
MOTOR DESIGN DATA		Cooling:	Fan-cooled through back channel	
HP: 7.5 RPM: 3600 Frame size: 213TC  Volts: Hertz: 60 Hz Phase: 3	Enclosure: TEFC	Ambient temperature:	-10°C to +45°C up to 1000 meters above sea level (+14°F to +113°F, 3300 ft)	
Efficiency: NEMA premium 12.12		Analog 1/0:	Two current or voltage inputs, one speed output	
		Digital ı/o:	Two inputs, two outputs	
MAXIMUM PUMP OPERATING CO	ONDITIONS	Pulse inputs:	Two programmable	
ANSI 125 - (CONSTRUCTION: BF)		Relay outputs:	Two programmable	
175 psig at 150°F (12 bar at 65°C)		Communication port:	1-RS485	
100 psig at 300°F (7 bar at 150°C)				
<b>ANSI 250 - (CONSTRUCTION: DBF)</b> 375 psig at 150°F (26 bar at 65°C)		guaranty performance to any sy meet a system wide specificatio	Irive via built-in DC line reactors. This does not stem wide harmonic specification or the costs to n. If supplied with the system electrical details, simulation of the system wide harmonics. If	

#### FLOW READOUT ACCURACY

260 psig at 300°F (21 bar at 150°C)

The Design Envelope model selected will provide flow reading on the controls local keypad & digitally for the BMS. The model readout will be factory tested to ensure  $\pm 5\%$  accuracy.

# MECHANICAL SEAL DATA

harmonic mitigation and the costs for such mitigation.

Seal type: AB2 Stationary seat: Sintered silicon carbide
Secondary seal: Viton Rotating hardware: Stainless steel

system harmonic levels are exceeded Armstrong can also recommend additional

**Spring:** Stainless steel

2

# **OPTIONS**

## SENSORLESS BUNDLE (STANDARD)



Operation of pump without a remote sensor. Includes:

- Sensorless control
- Flow readout
- Constant flow
- Constant pressure

Minimum system pressure to be maintained ft (m)

\* If minimum maintained system pressure is not known: Default to 40% of design head

#### ☐ PARALLEL SENSORLESS



Operation of multiple pumps without a remote sensor

Minimum system pressure to be maintained ft (m)

\* If minimum maintained system pressure is not known: Default to 40% of design head

### ☐ ENERGY PERFORMANCE BUNDLE



Provides energy savings on oversized systems by adjusting pump parameters to on-site conditions. Includes:

- Auto-flow balancing Automatically determines control curve between design flow at on-site system head, and minimum (zerohead) flow for energy savings
- Maximum flow control Limits flow rate to pre-set maximum for potential energy savings

Maximum flow rate gpm (L/s)

\*Only available if sensorless bundle is enabled

### □ PROTECTION BUNDLE



Protects other flow sensitive equipment by setting limits of pump operation. Includes:

- Minimum flow control Attempts to maintain flow rate to pre-set minimum to protect equipment in system
- Bypass valve control Actuates a bypass valve to protect flow sensitive equipment if pre-set minimum flow rate is reached

Minimum flow rate gpm (L/s)

# □ ZONE OPTIMIZATION BUNDLE



Controls pumps to ensure multiple zones are satisfied for heating or cooling

 2 sensor control - Controls pumps in a 2-zone application to ensure both zones are always satisfied for heating or cooling

#### $\square$ DUAL SEASON SETUP



Pre-sets heating and cooling parameters for pumps in 2-pipe systems

#### Cooling

-		
Duty point	gpm (L/s) at	ft (m)
Minimum syster	n pressure to be maint	ained
	ft (m)	
Heating		
Duty point	gpm (L/s) at	ft (m)
Minimum syster	n pressure to be maint	ained
	ft (m)	

## **OPTIONAL SERVICES**

## **ON-SITE PUMP COMMISSIONING**



Where purchased and applicable, onsite commissioning by an Armstrong representative will include setting up communication with the Pump (not wiring to BAS), adjusting parameters to match on-site conditions, register the pumps for enhanced warranty and connect the pumps to the router as part of the activation of Pump Manager.

#### **PUMP MANAGER**



As a Performance Management Service, Pump Manager is an online automated fault detection and diagnostic service for sustained performance and enhanced reliability. It includes advanced trending, alerts of variance in performance and automated reports.


Available in yearly increments. Includes an option for a price discount on the Extended Warranty Service.

<sup>\*</sup>Only available if sensorless bundle is enabled

<sup>\*</sup>The Service requires an active internet connection.

3


## **EXTENDED SPEED**



Performance curves are for reference only.

Confirm current performance data with Armstrong ACE Online selection software.

## INDOOR



## **DIMENSION DATA**

INDOOR (UL TYPE 12/ODP)

Frame size: 213TC

**Size:** 3×2.5×6

**HP:** 7.5

**RPM:** 3600

**HA:** 14.00 (355)

нв: 33.00 (838)

**HC:** 32.25 (819)

**HD:** 9.25 (235)

**HE:** 6.37 (162)

**HF:** 14.50 (368)

**2HF:** 29.00 (737)

**HG:** 3.00 (76)

**HI:** 29.52 (750)

**HL:** 4.50 (114)

**HV:** 14.42 (366)

**NaN1:** 2.00 (51)

**NaN2:** 7.95 (202)


**x:** 8.25 (210)

**Y:** 4.00 (102)

**Weight:** 366 (165.9)

Dimensions - inch (mm) Weight - lbs (kg)

- Tolerance of ±0.125" (±3 mm) should be used
- For exact installation, data please write factory for certified dimensions



#### TORONTO

23 BERTRAND AVENUE TORONTO, ONTARIO CANADA M1L 2P3 +1 416 755 2291

#### BUFFALO

93 EAST AVENUE NORTH TONAWANDA, NEW YORK U.S.A. 14120-6594 +1 716 693 8813

#### BIRMINGHAM

HEYWOOD WHARF, MUCKLOW HILL HALESOWEN, WEST MIDLANDS UNITED KINGDOM B62 8DJ +44 (0) 8444 145 145

## MANCHESTER

WOLVERTON STREET
MANCHESTER
UNITED KINGDOM
M11 2ET
+44 (0) 8444 145 145

#### BANGALORE

#59, FIRST FLOOR, 3RD MAIN MARGOSA ROAD, MALLESWARAM BANGALORE, INDIA 560 003 +91 (0) 80 4906 3555

#### SHANGHAI

UNIT 903, 888 NORTH SICHUAN RD. HONGKOU DISTRICT, SHANGHAI CHINA 200085 +86 (0) 21 5237 0909

### SÃO PAULO

RUA JOSÉ SEMIÃO RODRIGUES AGOSTINHO, 1370 GALPÃO 6 EMBU DAS ARTES SAO PAULO, BRAZIL +55 11 4785 1330

ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934

ARMSTRONGFLUIDTECHNOLOGY.COM

