

Date:

Date: ___

Date:

DESIGN ENVELOPE 4280 END SUCTION

50-125 (2×1.5×5) | 4012-004.0 | SUBMITTAL

File No: 103.5717IEC

Date: MARCH 25, 2021

Supersedes: 103.5717IEC

Date: SEPTEMBER 5, 2019

Job:		Representati
		Order No:
Engineer:	_	Submitted by
Contractor:		Approved by
PUMP DESIGN DATA		. DE
No. of pumps:	Tag:	
Capacity:L/s (USgpm)		:
Liquid:		•
Temperature:°C (°F)	Specific gravity:	:
Suction: 50 mm (2")	Discharge: 40 mm	(1.5")
MEI ≥ 0.70		
MATERIALS OF CONSTRUCT □ PN 16 CONSTRUCTION: LPDESF E-coated ductile iron A536 Gr □ PN 25		fitted F t
CONSTRUCTION: HPDESF E-coated ductile iron A536 Gr	120-90-2, stainless	fitted
MAXIMUM PUMP OPERATIN	IG CONDITIONS	
 □ PN 16 16 bar at 49°C (232 psig at 120° 7 bar at 150°C (100 psig at 300° □ PN 25 25 bar at 65°C (362 psig at 149° 	°F)	
21 bar at 150°C (304 psig at 300		
FLOW READOUT ACCURACY		
The Design Envelope model selecte on the controls local keypad & digitareadout will be factory tested to ens	ally for the BMS. The m	

MECHANICAL SEAL DESIGN DATA

Rotating hardware: Stainless steel

Secondary seal: EPDM **Spring:** Stainless steel

Seal type: 2A

Stationary seat: Silicone carbide

DEPM MOTOR AND CONTROL DATA

kW: 4.0

RPM: 3600

Motor enclosure: TEFC

Volts:

Phase: 3
Efficiency: IE5

Orientation: □ L5 (default) □ L6

Protocol (standard): □ BACnetTM MS/TP

□ BACnet[™] TCP/IP□ Modbus RTU

Control enclosure: ☐ Indoor - IP 55

used disconnect switch: Consult factory

EMI/RFI control: Integrated filter designed to

meet EN61800-3

Harmonic suppression: Equivalent: 5% Ac line reac-

tor - Supporting IEEE 519-1992

requirements**

Cooling: Fan-cooled, surface cooling

Ambient temperature: -10°C to +45°C up to 1000 meters

above sea level (+14° F to +113° F ,

3300 ft)

Analog I/o: Two inputs, one output. Output

can be configured for voltage

or current

Digital I/o: Two inputs, two outputs. Out-

puts can be configured as inputs

Relay outputs: Two programmable

Communication port: 1-RS485

** If supplied with the system electrical details, Armstrong will run a computer simulation of the system wide harmonics. If system harmonic levels are exceeded Armstrong can also recommend additional harmonic mitigation and the costs for such mitigation.

FLUID TYPE	ALL GLYCOLS > 30% WT CONC		ALL OTHER NON-POTABLE FLUIDS		POTABLE (DRINKING) WATER	
Temperature	up to 93°C / 200°F	over 93°C / 200°F	up to 93°C / 200°F	over 93°C / 200°F	up to 93°C / 200°F	over 93°C / 200°F
Rotating face	Silicone carbide		Resin bonded carbon	Antimony loaded carbon	Resin bonded carbon	
Seat elastomer	EPDM (L-cup)	EPDM (O-ring)	EPDM (L-cup)	EPDM (O-ring)	EPDM (L-cup)	EPDM (0-ring)
Material code	SCsc L EPSS 2A	SCsc o epss 2A	C-SC L EPSS 2A	ACsc o epss 2a	C-SC L EPSS 2A	C-SC O EPSS 2A

2

OPTIONS

SENSORLESS BUNDLE (STANDARD)



Operation of pump without a remote sensor. Includes:

- Sensorless control
- Flow readout
- Constant flow
- Constant pressure

Minimum system pressure to be maintained m (ft)

* If minimum maintained system pressure is not known: Default to 40% of design head

☐ PARALLEL SENSORLESS



Operation of multiple pumps without a remote sensor

Minimum system pressure to be maintained m (ft)

* If minimum maintained system pressure is not known: Default to 40% of design head

☐ ENERGY PERFORMANCE BUNDLE



Provides energy savings on oversized systems by adjusting pump parameters to on-site conditions. Includes:

- Auto-flow balancing Automatically determines control curve between design flow at on-site system head, and minimum (zero-head) flow for energy savings
- Maximum flow control Limits flow rate to pre-set maximum for potential energy savings

Maximum flow rate L/s (gpm)

☐ PROTECTION BUNDLE



Protects other flow sensitive equipment by setting limits of pump operation. Includes:

- Minimum flow control Attempts to maintain flow rate to pre-set minimum to protect equipment in system
- Bypass valve control Actuates a bypass valve to protect flow sensitive equipment if pre-set minimum flow rate is reached

Minimum flow rate L/s (gpm)

\square DUAL SEASON SETUP



Pre-sets heating and cooling parameters for pumps in 2-pipe systems

Cooling

Duty point	L/s (gpm) at m (ft)
Minimum system pre m (essure to be maintained (ft)
Heating	
Duty point	L/s (gpm) at m (ft)
Minimum system pre	essure to be maintained m (ft)

OPTIONAL SERVICES

ON-SITE PUMP COMMISSIONING



PUMP MANAGER



Online service for sustained pump performance and enhanced reliability.

Available in 3 or 5 year terms

- * Requires an internet connection to be provided by building
- * Includes an extended warranty for parts and labour (wearable parts excluded)


^{*}Only available if sensorless bundle is enabled

^{*}Available in single pump operation only

^{*}Only available if sensorless bundle is enabled

^{*}Available in single pump operation only


3




Performance curves are for reference only.

Confirm current performance data with Armstrong ADEPT Quote or ADEPT Select selection software.

STANDARD



SEISMIC MOUNT OPTION



DIMENSION DATA

STANDARD

Size: 2×1.5×5

κW: 4.0

RPM: 3000

HA: 262 (10.32)

HD: 222 (8.75)

HI: 464 (18.27)

HV: 208 (8.18)

x: 178 (7.00)

y: 102 (4.00)

Free & operating height: 95 (3.75)

Weight: 42 (92.6)

SPRING DATA

Rated Capacity per spring kgs (lbs):

Rated Deflection mm (inch):

Mount Constant kg/mm (lbs/in):

25 (1.00)
2.0 (113)

SEISMIC MOUNT OPTION

2E: 146 (5.75)
F: 102 (4.00)
G: 152 (6.00)
H: 12 (0.50)
HA: 262 (10.32)
HD: 254 (10.00)
N: 166 (6.52)

Free & operating height:

Max. horizontal static G rating:


- Dimensions mm (inch)
- Weight kg (lbs)
- Tolerance of ±3 mm (±0.125") should be used
- For exact installation, data please write factory for certified dimensions


NOTE:

All springs have additional travel to solid equal to 50% of the rated deflection.


4


STANDARD





SEISMIC MOUNT OPTION





TORONTO

+1 416 755 2291

BUFFALO

+1 716 693 8813

BIRMINGHAM

+44 (0) 8444 145 145

MANCHESTER

+44 (0) 8444 145 145

BANGALORE

+91 (0) 80 4906 3555

SHANGHAI

+86 (0) 21 5237 0909

SÃO PAULO

+55 11 4785 1330

LYON

+33 (0) 420 102 625

DUBAI

+971 4 887 6775

MANNHEIM

+49 (0) 621 3999 9858

ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934

H DIA

8 HOLES

2E

ARMSTRONGFLUIDTECHNOLOGY.COM