

# **DESIGN ENVELOPE** DEPM IVS 4300 VIL 125-190 (5×5×7.5) | 1219-045.0 | **submittal**

File No: 100.5188IEC Date: FEBRUARY 08, 2024 Supersedes: NEW Date: NEW

Job:	Representative:		
	Order No:	Date:	
Engineer:	Submitted by:	Date:	
Contractor:	Approved by:	Date:	

# PUMP DESIGN DATA

No. of pumps:	Tag:
Capacity:L/s (USgpm)	Head:m (ft)
Liquid:	Viscosity:
Temperature: °C (°F)	Specific gravity:
Suction: 125 mm (5")	Discharge: 125 mm (5")

MEI ≥ 0.70

# MATERIALS OF CONSTRUCTION

## 🗆 pn 16

**CONSTRUCTION: SF** E-coated cast iron, 316 stainless steel fitted Upgrade impeller to duplex stainless steel fitted (DF)

## D PN 25

CONSTRUCTION: DSF

E-coated ductile iron, 316 stainless steel fitted Upgrade impeller to duplex stainless steel fitted (DDF)

## MAXIMUM PUMP OPERATING CONDITIONS

## □ pn 16

16 bar at 49°C (232 psig at 120°F) 7 bar at 150°C (100 psig at 300°F)

## □ PN 25

25 bar at 65°C (362 psig at 149°F) 21 bar at 150°C (304 psig at 300°F)

# MECHANICAL SEAL DESIGN DATA

See file no. 43.50 for standard mechanical seal details as indicated below

Armstrong seal reference number

□ c1 (a) □ Others: \_\_\_

DEPMH MOTOR AND CONTROLS DATA

kW:	45	
Motor enclosure:	TEFC	
Volts:		
Phase:	3	
Efficiency:	IE5	
Orientation:	□ L1 (default) □ L2 □ L3 □ L4	
	□ BACNEt <sup>™</sup> MS/TP □ BACNEt <sup>™</sup> TCP/IP	
	□ Modbus rtu	
Control enclosure:	□ Indoor – IP 55 □ Outdoor – IP 66	
	□ Option for Indoor units	
Fused disconnect switch:		
EMI/RFI control:	Integrated filter designed to meet	
	EN61800-3	
Harmonic suppression:	Dual pc-link reactors (Equivalent: 5% AC	
	line reactor) Supporting IEEE 519-1992	
	requirements**	
Cooling:	Fan-cooled through back channel	
Ambient temperature:	-10°C to +45°C up to 1000 meters above	
	sea level (+14°F to +113°F, 3300 ft)	
Analog ı/o:	Two current or voltage inputs,	
	one speed output	
•	Two inputs, two outputs	
•	Two programmable	
	Two programmable	
Communication port:	1-RS485	

Communication port: 1-RS485

\*\* If supplied with the system electrical details, Armstrong will run a computer simulation of the system wide harmonics. If system harmonic levels are exceeded Armstrong can also recommend additional harmonic mitigation and the costs for such mitigation.

## FLOW READOUT ACCURACY

The Design Envelope model selected will provide flow reading on the controls local keypad & digitally for the BMS and Pump Manager. The model readout will be factory tested to ensure  $\pm$ 5% accuracy. 2

# OPTIONS

# SENSORLESS BUNDLE (STANDARD)



Operation of pump without a remote sensor. Includes:

- Sensorless control
- Flow readout
- Constant flow
- Constant pressure

Minimum system pressure to be maintained

m (ft)

 $^{\star}\,$  If minimum maintained system pressure is not known: Default to 40% of design head





Operation of multiple pumps without a remote sensor

Minimum system pressure to be maintained m (ft)

\* If minimum maintained system pressure is not known: Default to 40% of design head

# ENERGY PERFORMANCE BUNDLE



Provides energy savings on oversized systems by adjusting pump parameters to on-site conditions. Includes:

- Auto-flow balancing Automatically determines control curve between design flow at on-site system head, and minimum (zerohead) flow for energy savings
- Maximum flow control Limits flow rate to pre-set maximum for potential energy savings

Maximum flow rate L/s (gpm)

 $^{\star} \textsc{Only}$  available if sensorless bundle is enabled

# □ **PROTECTION BUNDLE**



Protects other flow sensitive equipment by setting limits of pump operation. Includes:

- Minimum flow control Attempts to maintain flow rate to pre-set minimum to protect equipment in system
- Bypass valve control Actuates a bypass valve to protect flow sensitive equipment if pre-set minimum flow rate is reached

Minimum flow rate L/s (gpm)

\*Only available if sensorless bundle is enabled

# **ZONE OPTIMIZATION BUNDLE**



Controls pumps to ensure multiple zones are satisfied for heating or cooling

• 2 sensor control – Controls pumps in a 2-zone application to ensure both zones are always satisfied for heating or cooling

# DUAL SEASON SETUP



Pre-sets heating and cooling parameters for pumps in 2-pipe systems

Cooling				
Duty point		L/s (gpm) at		m (ft)
Minimum s	ystem pre	essure to be m	aintaineo	t
	m	(ft)		

# Heating

Duty point L/s (gpm) at m (ft) Minimum system pressure to be maintained m (ft)

# **OPTIONAL SERVICES**

# **ON-SITE PUMP COMMISSIONING**



Where purchased and applicable, onsite commissioning by an Armstrong representative will include setting up communication with the Pump (not wiring to BAS), adjusting parameters to match on-site conditions, register the pumps for enhanced warranty and connect the pumps to the router as part of the activation of Pump Manager.

# PUMP MANAGER



As a Performance Management Service, Pump Manager is an online automated fault detection and diagnostic service for sustained performance and enhanced reliability. It includes advanced trending, alerts of variance in performance and automated reports.

Available in yearly increments. Includes an option for a price discount on the Extended Warranty Service.

\*The Service requires an active internet connection.

:

3

# DIMENSION DATA

	INDOOR	OUTDOOR
	(IP55/TEFC)	(IP66/TEFC)
Size:	125-190	125-190
кW:	45	45
AB:	1150 (45.28)	1250 (49.21
D:	312 (12.28)	312 (12.28)
E:	584 (22.99)	584 (22.99)
F:	908 (35.75)	908 (35.75)
Ρ:	290 (11.42)	290 (11.42)
S:	323 (12.72)	323 (12.72)
SD:	635 (25.00)	635 (25.00)
т:	191 (7.52)	191 (7.52)
XY:	1300 (51.18)	1300 (51.18
Weight:	380 (837.8)	383 (844.4)

Performance curves are for reference only.

50

800

45

700

Σ

Confirm current performance data with Armstrong ADEPT Quote or ADEPT Select selection software.

70

FLOW

80

1250

60

900

1000

Dimensions – mm (inch) Weight – kg (lbs)

:

- Tolerance of ±3 mm (±0.125") should be used
- For exact installation, data please write factory for certified dimensions

## INDOOR

70

220

200 - 60


180


HEAD

120 -35


100 - 30 -90 - 30 -

160 - 50





## OUTDOOR




1219-045.0


100

90

. 1500



# CONTROL ORIENTATIONS



#### TORONTO

23 BERTRAND AVENUE, TORONTO, ONTARIO, CANADA, M1L 2P3 +1 416 755 2291

#### BUFFALO

93 EAST AVENUE, NORTH TONAWANDA, NEW YORK, U.S.A., 14120-6594 +1 716 693 8813

### DROITWICH SPA

POINTON WAY, STONEBRIDGE CROSS BUSINESS PARK, DROITWICH SPA, WORCESTERSHIRE, UNITED KINGDOM, WR9 OLW +44 121 550 5333

#### MANCHESTER

WOLVERTON STREET, MANCHESTER UNITED KINGDOM, M11 2ET +44 161 223 2223

#### BANGALORE

#18, LEWIS WORKSPACE, 3<sup>80</sup> FLOOR, OFF MILLERS - NANDIDURGA ROAD, JAYAMAHAL CBD, BENSON TOWN, BANGALORE, INDIA 560 046 +91 80 4906 3555

#### SHANGHAI

unit 903, 888 north sichuan rd. hongkou district, shanghai china, 200085 +86 21 5237 0909

#### BEIJING

ROOM 1612, NANYIN BUILDING NO.2 NORTH EAST THRID RING ROAD CHAOYANG DISTRICT, BEIJING, CHINA 100027 +86 21 5237 0909

#### SÃO PAULO

rua josé semião rodrigues agostinho, 1370 galpão 6 embu das artes, sao paulo, brazil +55 11 4785 1330

## LYON

93 RUE DE LA VILLETTE LYON, 69003 FRANCE +33 4 26 83 78 74

#### DUBAI

JAFZA VIEW 19, OFFICE 402 P.O.BOX 18226 JAFZA, DUBAI - UNITED ARAB EMIRATES +971 4 887 6775

#### JIMBOLIA

STR CALEA MOTILOR NR. 2C JIMBOLIA 305400, JUD.TIMIS ROMANIA +40 256 360 030

#### FRANKFURT

WESTERBACHSTRASSE 32, D-61476 KRONBERG IM TAUNUS GERMANY +49 6173 999 77 55

ARMSTRONG FLUID TECHNOLOGY<sup>®</sup> ESTABLISHED 1934

ARMSTRONGFLUIDTECHNOLOGY.COM