

DESIGN ENVELOPE 4380 VIL

1.25×1.25×5 (32-125) | 1205-001.5 | SUBMITTAL

_____ Representative: _

File No: 101.5736

Date: NOVEMBER 08, 2021

Supersedes: NEW

Date: NEW

	Orde	er No:	Date:	
Engineer: Su Contractor: A		nitted by:		
		roved by:		
PUMP DESIGN DATA		DEPM MOTOR AND CO	ONTROL DATA	
No. of pumps:	Tag:	HP:	1.5	
Capacity:USgpm (L/s)	_	RPM:	3000	
Liquid:		Motor enclosure:	TEFC	
		Volts / Phase:	□ 200-240V/1ph □ 380-480V/3ph	
Temperature: °F (°C)		:	For 200-240V/3ph or 575V/3ph,	
Suction: 1.25" (32 mm)	Discharge: 1.25" (32 mm)		see File #: 101.5713	
UL STD 778 & CSA STD C22.2 NO.108 certified		Efficiency:	IE5 □ L5 (default) □ L6	
Test report is supplied with each p			□ BACnet™ MS/TP □ BACnet™ TCP/IF	
rest report is supplied with each p	, amp	: Trotocor (Standard).	☐ Modbus RTU	
		Control enclosure:	☐ Indoor – UL TYPE 12	
MATERIALS OF CONSTRUCT	ION	:	☐ Outdoor – UL TYPE 12,	
☐ ANSI 125		•	tested to TYPE 4X	
CONSTRUCTION: LPDEBF		Fused disconnect switch:	h: See File 100.8131	
E-coated ductile iron A 536 Gr	565-45-12, bronze fitted	EMI/RFI control:	Integrated filter designed to meet EN61800-3	
		Harmonic suppression:	Equivalent: 5% Ac line reactor - Sup-	
MAXIMUM PUMP OPERATION	IG CONDITIONS	:	porting IEEE 519-1992 requirements*	
☐ ANSI 125		· ·	Fan-cooled, surface cooling	
175 psig at 150°F (12 bar at 65°C)		: Ambient temperature:	-10°C to +40°C up to 1000 meters abov	
140 psig at 250°F (10 bar at 121°C)		Analaarra	sea level (+14°F to +104°F, 3300 ft)	
		Analog I/o:	Two inputs, one output. Output can be configured for voltage or current	
		: Digital (/o:	Two inputs, two outputs. Outputs ca	
FLOW READOUT ACCURACY		. Digital 1/0.	be configured as inputs	
	dough and dar file of	: Relay outputs:	Two programmable	
The Design Envelope model selected will provide flow reading on the controls local knypad & digitally for the DMS. The model		Communication port:		

MECHANICAL SEAL DESIGN DATA

on the controls local keypad & digitally for the BMS. The model readout will be factory tested to ensure ±5% accuracy.

Seal type: 2A Stationary seat: Silicone carbide Secondary seal: EPDM Spring: Stainless steel

Rotating hardware: Stainless steel

FLUID TYPE	ALL GLYCOLS > 30% WT CONC		ALL OTHER NON-POTABLE FLUIDS		POTABLE (DRINKING) WATER	
Temperature	up to 200°F / 93°C	over 200°F / 93°C	up to 200°F / 93°C	over 200°F / 93°C	up to 200°F / 93°C	over 200°F / 93°C
Rotating face	Silicone carbide		Resin bonded carbon	Antimony loaded carbon	Resin bonded carbon	
Seat elastomer	EPDM (L-cup)	EPDM (o-ring)	EPDM (L-cup)	EPDM (0-ring)	EPDM (L-cup)	EPDM (o-ring)
Material code	SCsc L EPSS 2A	SCsc o epss 2A	C-SC L EPSS 2A	ACsc o epss 2A	C-SC L EPSS 2A	C-SC O EPSS 2A

** If supplied with the system electrical details, Armstrong will run a computer simulation of the system wide harmonics. If system harmonic levels are exceeded Armstrong can also recommend additional harmonic mitigation and the costs for such mitigation.

2

OPTIONS

SENSORLESS BUNDLE (STANDARD)



Operation of pump without a remote sensor. Includes:

- Sensorless control
- Flow readout
- Constant flow
- Constant pressure

Minimum system pressure to be maintained ft (m)

* If minimum maintained system pressure is not known: Default to 40% of design head

□ PARALLEL SENSORLESS



Operation of multiple pumps without a remote sensor

Minimum system pressure to be maintained ft (m)

* If minimum maintained system pressure is not known: Default to 40% of design head

☐ ENERGY PERFORMANCE BUNDLE



Provides energy savings on oversized systems by adjusting pump parameters to on-site conditions. Includes:

- Auto-flow balancing Automatically determines control curve between design flow at on-site system head, and minimum (zerohead) flow for energy savings
- Maximum flow control Limits flow rate to pre-set maximum for potential energy savings

Maximum flow rate gpm (L/s)

□ PROTECTION BUNDLE



Protects other flow sensitive equipment by setting limits of pump operation. Includes:

- Minimum flow control Attempts to maintain flow rate to pre-set minimum to protect equipment in system
- Bypass valve control Actuates a bypass valve to protect flow sensitive equipment if pre-set minimum flow rate is reached

Minimum flow rate gpm (L/s)

□ DUAL SEASON SETUP



Pre-sets heating and cooling parameters for pumps in 2-pipe systems

Cooling

Cooling		
Duty point	gpm (L/s) at	ft (m)
Minimum system	m pressure to be maint	ained
	ft (m)	
Heating		
Duty point	gpm (L/s) at	ft (m)
Minimum system	m pressure to be maint	ained
	ft (m)	

OPTIONAL SERVICES

ON-SITE PUMP COMMISSIONING



PUMP MANAGER



Online service for sustained pump performance and enhanced reliability.

Available in 3 or 5 year terms

- * Requires an internet connection to be provided by building
- * Includes an extended warranty for parts and labour (wearable parts excluded)


^{*}Only available if sensorless bundle is enabled

^{*}Available in single pump operation only

^{*}Only available if sensorless bundle is enabled

^{*}Available in single pump operation only


3




Performance curves are for reference only.


Confirm current performance data with Armstrong ADEPT Quote or ADEPT Select selection software.

OUTDOOR



INDOOR






DIMENSION DATA

	INDOOR (UL TYPE 12/TEFC)	OUTDOOR (UL TYPE 12, TESTED TO TYPE 4X)
Size:	1.25×1.25×5	1.25×1.25×5
HP:	1.5	1.5
RPM:	3000	3000
Frame:	71	71
AB:	14.53 (369)	15.66 (398)
B:	3.51 (89)	3.51 (89)
c:	3.20 (81)	3.20 (81)
CI:	_	2.75 (70)
D:	5.26 (134)	5.26 (134)
E:	5.99 (152)	6.41 (163)
s:	5.76 (146)	5.76 (146)
SD:	11.02 (280)	11.02 (280)
T:	3.00 (76)	3.00 (76)
Weight:	50 (22.7)	50 (22.7)

Dimensions - inch (mm) Weight - lbs (kg)

- Tolerance of ± 0.125 " (± 3 mm) should be used
- For exact installation, data please write factory for certified dimensions

CONTROL ORIENTATIONS



TORONTO

23 BERTRAND AVENUE TORONTO, ONTARIO CANADA, M1L 2P3 +1 416 755 2291

BUFFALO

93 EAST AVENUE NORTH TONAWANDA, NEW YORK U.S.A., 14120-6594 +1 716 693 8813

DROITWICH SPA

POINTON WAY,
STONEBRIDGE CROSS BUSINESS PARK
DROITWICH SPA, WORCESTERSHIRE
UNITED KINGDOM, WR9 OLW
+44 8444 145 145

MANCHESTER

WOLVERTON STREET
MANCHESTER
UNITED KINGDOM, M11 2ET
+44 8444 145 145

BANGALORE

#59, FIRST FLOOR, 3RD MAIN MARGOSA ROAD, MALLESWARAM BANGALORE, INDIA, 560 003 +91 80 4906 3555

SHANGHAI

unit 903, 888 north sichuan rd. Hongkou district, shanghai China, 200085 +86 21 5237 0909

SÃO PAULO

RUA JOSÉ SEMIÃO RODRIGUES AGOSTINHO, 1370 GALPÃO 6 EMBU DAS ARTES SAO PAULO, BRAZIL +55 11 4785 1330

LYON

93 RUE DE LA VILLETTE LYON, 69003 FRANCE +33 4 26 83 78 74

DUBAI

JAFZA VIEW 19, OFFICE 402 P.O.BOX 18226 JAFZA, DUBAI - UNITED ARAB EMIRATES +971 4 887 6775

MANNHEIM

DYNAMOSTRASSE 13 68165 MANNHEIM GERMANY +49 621 3999 9858

JIMBOLIA

STR CALEA MOTILOR NR 2C PO: 305400, JIMBOLIA ROMANIA +40 256 360 030

ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934