

DESIGN ENVELOPE 4380 VIL 1.5×1.5×3 (40-80)

File No: 101.5741 Date: NOVEMBER 08, 2021 Supersedes: NEW Date: NEW

1503-001.5 **SUBMITTAL**

Job:	Representative:	
	Order No:	Date:
Engineer:	Submitted by:	Date:
Contractor:	Approved by:	_Date:

PUMP DESIGN DATA

No. of pumps:		Tag:
Capacity:US	gpm (L/s)	Head:ft (m)
Liquid:		Viscosity:
Temperature:	°F (°C)	Specific gravity:
Suction: 1.5" (40 mm)		Discharge: 1.5" (40 mm)

UL STD 778 & CSA STD C22.2 NO.108 certified

Test report is supplied with each pump

MATERIALS OF CONSTRUCTION

□ ANSI 125 CONSTRUCTION: LPDEBF E-coated ductile iron A 536 Gr 565-45-12, bronze fitted

MAXIMUM PUMP OPERATING CONDITIONS

□ ANSI 125

175 psig at 150°F (12 bar at 65°C) 140 psig at 250°F (10 bar at 121°C)

FLOW READOUT ACCURACY

The Design Envelope model selected will provide flow reading on the controls local keypad & digitally for the BMS. The model readout will be factory tested to ensure ±5% accuracy.

MECHANICAL SEAL DESIGN DATA

Secondary seal: EPDM

** If supplied with the system electrical details, Armstrong will run a computer simulation of the system wide harmonics. If system harmonic levels are exceeded Armstrong can also recommend additional harmonic mitigation and the costs for such mitigation.

Seal type: 2A Stationary seat: Silicone carbide Rotating hardware: Stainless steel

FLUID TYPE	ALL GLYCOLS >	→ 30% WT CONC	ALL OTHER NO	N-POTABLE FLUIDS	POTABLE (DRI	NKING) WATER
Temperature	up to 200°F / 93°C	over 200°F / 93°C	up to 200°F / 93°C	over 200°F / 93°C	up to 200°F / 93°C	over 200°F / 93°C
Rotating face	Silicone	carbide	Resin bonded carbon	Antimony loaded carbon	Resin bond	led carbon
Seat elastomer	EPDM (L-CUP)	EPDM (O-ring)	EPDM (L-CUP)	EPDM (O-ring)	EPDM (L-CUP)	EPDM (O-ring)
Material code	SCsc l epss 2A	SCsc o epss 2A	C-SC L EPSS 2A	ACsc o epss 2A	C-SC L EPSS 2A	C-SC O EPSS 2A

DEPM MOTOR AND CONTROL DATA

HP:	1.5
RPM:	4500
Motor enclosure:	TEFC
Volts / Phase:	🗆 200-240V/1ph 🛛 380-480V/3ph
	For 200-240V/3ph or 575V/3ph,
	see File #: 101.5503
Efficiency:	IE5
Orientation:	□ L5 (default) □ L6
Protocol (standard):	□ BACNEt [™] MS/TP □ BACNEt [™] TCP/IP
	□ Modbus rtu
Control enclosure:	🗌 Indoor – UL TYPE 12
	🗆 Outdoor – UL TYPE 12,
	tested to TYPE 4X
Fused disconnect switch:	See File 100.8131
EMI/RFI control:	Integrated filter designed to meet
	en61800-3
Harmonic suppression:	Equivalent: 5% Ac line reactor - Sup-
	porting IEEE 519-1992 requirements**
Cooling:	Fan-cooled, surface cooling
Ambient temperature:	-10°C to +40°C up to 1000 meters above
	sea level (+14°F to +104°F, 3300 ft)
Analog ı/o:	Two inputs, one output. Output can
	be configured for voltage or current
Digital ı/o:	Two inputs, two outputs. Outputs can
	be configured as inputs
• •	Two programmable
Communication port:	1-RS485

Spring: Stainless steel

Design Envelope 4380 VIL

2

OPTIONS

SENSORLESS BUNDLE (STANDARD)



Operation of pump without a remote sensor. Includes:

- Sensorless control
- Flow readout
- Constant flow
- Constant pressure

Minimum system pressure to be maintained

ft (m)

 If minimum maintained system pressure is not known: Default to 40% of design head

PARALLEL SENSORLESS



Operation of multiple pumps without a remote sensor

Minimum system pressure to be maintained ft (m)

* If minimum maintained system pressure is not known: Default to 40% of design head

ENERGY PERFORMANCE BUNDLE



Provides energy savings on oversized systems by adjusting pump parameters to on-site conditions. Includes:

- Auto-flow balancing Automatically determines control curve between design flow at on-site system head, and minimum (zerohead) flow for energy savings
- Maximum flow control Limits flow rate to pre-set maximum for potential energy savings

Maximum flow rate

ow rate gpm (L/s)

*Only available if sensorless bundle is enabled *Available in single pump operation only

PROTECTION BUNDLE



Protects other flow sensitive equipment by setting limits of pump operation. Includes:

- Minimum flow control Attempts to maintain flow rate to pre-set minimum to protect equipment in system
- Bypass valve control Actuates a bypass valve to protect flow sensitive equipment if pre-set minimum flow rate is reached

Minimum flow rate gpm (L/s)

DUAL SEASON SETUP



Pre-sets heating and cooling parameters for pumps in 2-pipe systems

Cooling

Duty point _____ gpm (L/s) at _____ ft (m) Minimum system pressure to be maintained ______ ft (m)

Heating

Duty point _____ gpm (L/s) at _____ ft (m) Minimum system pressure to be maintained ft (m)

*Available in single pump operation only

OPTIONAL SERVICES

ON-SITE PUMP COMMISSIONING



PUMP MANAGER




Online service for sustained pump performance and enhanced reliability.

Available in 3 or 5 year terms


- * Requires an internet connection to be provided by building
- * Includes an extended warranty for parts and labour (wearable parts excluded)


*Only available if sensorless bundle is enabled




Performance curves are for reference only. Confirm current performance data with Armstrong **ADEPT Quote** or **ADEPT Select** selection software.


INDOOR





OUTDOOR





DIMENSION DATA

	INDOOR (UL TYPE 12/TEFC)	OUTDOOR (UL TYPE 12, TESTED TO TYPE 4X)
Size:	1.5×1.5×3	1.5×1.5×3
HP:	1.5	1.5
RPM:	4500	4500
Frame:	71	71
AB:	13.17 (334)	14.30(363)
в:	3.09 (78)	3.09 (78)
c:	2.27 (58)	2.27 (58)
CI:	-	2.75 (70)
D:	4.59 (116)	4.59 (116)
E:	5.99 (152)	6.41 (163)
s:	5.37 (136)	5.37 (136)
SD:	9.96 (253)	9.96 (253)
т:	2.93 (74)	2.93 (74)
Weight:	50 (22.7)	50 (22.7)


Dimensions – inch (mm) Weight – Ibs (kg)

÷

• Tolerance of ±0.125" (±3 mm) should be used

• For exact installation, data please write factory for certified dimensions

CONTROL ORIENTATIONS



TORONTO

23 BERTRAND AVENUE TORONTO, ONTARIO CANADA, M1L 2P3 +1 416 755 2291

BUFFALO

93 EAST AVENUE NORTH TONAWANDA, NEW YORK U.S.A., 14120-6594 +1 716 693 8813

DROITWICH SPA

POINTON WAY, STONEBRIDGE CROSS BUSINESS PARK DROITWICH SPA, WORCESTERSHIRE UNITED KINGDOM, WR9 OLW +44 8444 145 145

MANCHESTER

WOLVERTON STREET MANCHESTER UNITED KINGDOM, M11 2ET +44 8444 145 145

BANGALORE

#59, FIRST FLOOR, 3RD MAIN MARGOSA ROAD, MALLESWARAM BANGALORE, INDIA, 560 003 +91 80 4906 3555

SHANGHAI

unit 903, 888 north sichuan rd. hongkou district, shanghai china, 200085 +86 21 5237 0909

SÃO PAULO

rua josé semião rodrigues agostinho, 1370 galpão 6 embu das artes sao paulo, brazil +55 11 4785 1330

LYON

93 RUE DE LA VILLETTE LYON, 69003 FRANCE +33 4 26 83 78 74

DUBAI

JAFZA VIEW 19, OFFICE 402 P.O.BOX 18226 JAFZA, DUBAI - UNITED ARAB EMIRATES +971 4 887 6775

MANNHEIM

DYNAMOSTRASSE 13 68165 mannheim germany +49 621 3999 9858

JIMBOLIA

STR CALEA MOTILOR NR 2C PO: 305400, JIMBOLIA ROMANIA +40 256 360 030

ARMSTRONG FLUID TECHNOLOGY ESTABLISHED 1934

ARMSTRONGFLUIDTECHNOLOGY.COM