



SERIAL CARD OPTIONS	
RS-485 MODBUS RTU	
BACNET/IP	
BACNET MS/TP	
FTT10 LONWORKS	

- NOTES:**
- - TERMINAL POINT
  - ▲ - REMOTE DEVICE (BY OTHERS)
  - - WIRING (BY OTHERS)
  - - - - - WIRING (BY ARMSTRONG)
  - \_\_\_\_\_ WIRING (BY PANEL MANUFACTURER)
  - ① - CUSTOMER MUST PROVIDE BRANCH-CIRCUIT PROTECTION.
  - ② - ALL PANELS TO BE MANUFACTURED AND LABELED IN ACCORDANCE WITH UL/cUL508 AND OPTIONAL CSA.
  - ③ - FOR PANEL WIRE AND CONDUIT SIZES, REFER TO AES2011010
  - ④ - MUST USE FUSE SIZE & TYPE RECOMMENDED BY DRIVE MANUFACTURER

REV	DESCRIPTION	DATE	BY
08	Revised as per EOI#108344	2018/06/12	MS
07	Revised as per EOI#108307	2018/05/16	MS
06	Revised as per EOI#108159	2018/02/22	MS
05	Revised as per EOI #107288	2016/09/23	MS
04	Revised as per EOI #107250	2016/08/26	MS
03	Revised as per EOI #106562	2015/06/04	MS
02	Revised as per EOI #106301	2014/10/22	MS
01	Revised as per EOI #106047	2014/03/12	JJK
ORG	Released as per ECO 105951	2013/12/12	JJK

PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ARMSTRONG PUMPS, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ARMSTRONG PUMPS, INC. IS PROHIBITED.	<table border="1"> <tr> <th>NAME</th> <th>DATE</th> </tr> <tr> <td>DRAWN: JJK</td> <td>2014/03/12</td> </tr> <tr> <td>CHECKED: CAP</td> <td>2014/03/12</td> </tr> <tr> <td>DESIGN APPROV: JJK</td> <td>2014/03/12</td> </tr> <tr> <td>CUSTOMER:</td> <td></td> </tr> </table>	NAME	DATE	DRAWN: JJK	2014/03/12	CHECKED: CAP	2014/03/12	DESIGN APPROV: JJK	2014/03/12	CUSTOMER:		<p><b>ARMSTRONG</b></p> <p><b>IVS 4 Pump Booster</b>  <b>Wiring Diagram</b></p> <p>SIZE: D DWG. NO: PTP/VS04M0-802 REV: 08</p> <p>SCALE: NONE WEIGHT: SHEET 01 of 01</p>
NAME	DATE											
DRAWN: JJK	2014/03/12											
CHECKED: CAP	2014/03/12											
DESIGN APPROV: JJK	2014/03/12											
CUSTOMER:												