



| SERIAL CARD OPTIONS | |
|---------------------|--|
| RS-485 MODBUS RTU | |
| BACNET/IP | |
| BACNET MS/TP | |
| FTT10 LONWORKS | |

- NOTES:**
- - TERMINAL POINT
 - ▲ - REMOTE DEVICE (BY OTHERS)
 - - WIRING (BY OTHERS)
 - - WIRING (BY ARMSTRONG)
 - - WIRING (BY PANEL MANUFACTURER)
 - ① - CUSTOMER MUST PROVIDE BRANCH-CIRCUIT PROTECTION.
 - ② - ALL PANELS TO BE MANUFACTURED AND LABELED IN ACCORDANCE WITH UL/cUL508 AND OPTIONAL CSA.
 - ③ - FOR PANEL WIRE AND CONDUIT SIZES, REFER TO AES2011010
 - ④ - MUST USE FUSE SIZE & TYPE RECOMMENDED BY DRIVE MANUFACTURER

| REV | DESCRIPTION | DATE | BY |
|-----|----------------------------|------------|-----|
| 08 | Revised as per EOI#108344 | 2018/06/12 | MS |
| 07 | Revised as per EOI#108307 | 2018/05/16 | MS |
| 06 | Revised as per EOI#108159 | 2018/02/22 | MS |
| 05 | Revised as per EOI #107288 | 2016/09/23 | MS |
| 04 | Revised as per EOI #107250 | 2016/08/26 | MS |
| 03 | Revised as per EOI #106562 | 2015/06/04 | MS |
| 02 | Revised as per EOI #106301 | 2014/10/22 | MS |
| 01 | Revised as per EOI #106047 | 2014/03/12 | JJK |
| ORG | Released as per ECO 105951 | 2013/12/12 | JJK |

| PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF ARMSTRONG PUMPS, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF ARMSTRONG PUMPS, INC. IS PROHIBITED. | <table border="1"> <tr> <th>NAME</th> <th>DATE</th> </tr> <tr> <td>DRAWN: JJK</td> <td>2013/03/12</td> </tr> <tr> <td>CHECKED: CAP</td> <td>2013/03/12</td> </tr> <tr> <td>QA: JJK</td> <td>2014/03/12</td> </tr> <tr> <td>MFG APPR: JJK</td> <td>2014/03/12</td> </tr> <tr> <td>ENGR APPR: JJK</td> <td>2014/03/12</td> </tr> <tr> <td>CUSTOMER:</td> <td></td> </tr> <tr> <td>JOB NO:</td> <td></td> </tr> </table> | NAME | DATE | DRAWN: JJK | 2013/03/12 | CHECKED: CAP | 2013/03/12 | QA: JJK | 2014/03/12 | MFG APPR: JJK | 2014/03/12 | ENGR APPR: JJK | 2014/03/12 | CUSTOMER: | | JOB NO: | | <p>ARMSTRONG</p> <p>TITLE: IVS 5 Pump Booster Wiring Diagram</p> <p>SIZE: D DWG. NO.: PTP/VS05M0-803 REV: 08</p> <p>SCALE: NONE WEIGHT: SHEET 01 of 01</p> |
|---|---|------|------|------------|------------|--------------|------------|---------|------------|---------------|------------|----------------|------------|-----------|--|---------|--|--|
| NAME | DATE | | | | | | | | | | | | | | | | | |
| DRAWN: JJK | 2013/03/12 | | | | | | | | | | | | | | | | | |
| CHECKED: CAP | 2013/03/12 | | | | | | | | | | | | | | | | | |
| QA: JJK | 2014/03/12 | | | | | | | | | | | | | | | | | |
| MFG APPR: JJK | 2014/03/12 | | | | | | | | | | | | | | | | | |
| ENGR APPR: JJK | 2014/03/12 | | | | | | | | | | | | | | | | | |
| CUSTOMER: | | | | | | | | | | | | | | | | | | |
| JOB NO: | | | | | | | | | | | | | | | | | | |